

Rule No. 16
SERVICE CONNECTIONS, METERS, AND CUSTOMER'S FACILITIES
(continued)

- C. 2. a. supply and agrees to remove all pumps and piping necessary for the utilization of this supply, the installation of backflow preventers will not be required.) (T)
 - b. Where salt water, or water otherwise contaminated, is available for industrial or fire protection purposes at the same premises. (T)
 - c. Where the premises are or may be engaged in industrial processes using or producing process water or liquid industrial wastes, or where the premises are or may be engaged in handling sewage or any other dangerous substances.
 - d. Where fresh water hydrants or other outlets are or may be installed on piers or docks.
 - e. Where the circumstances are such that there is special danger of backflow of sewage or other contaminated liquids through plumbing fixtures or water-using or treating equipment, or storage tanks and reservoirs.
 - f. Premises that have internal cross-connections that are not abated to the satisfaction of the utility or the health agency. (N)
 - g. Premises where cross-connections are likely to occur and entry is restricted so that cross-connection inspections cannot be made with sufficient frequency or at sufficiently short notice to assure that cross-connections do not exist.
 - h. Premises having a repeated history of cross-connections being established or reestablished. (N)
3. Type and Expense of Backflow Preventers (T)
- Any backflow preventer utilized shall be of the type and design specified and approved for the circumstances in Section 7604, Title 17 of the California Code of Regulations, except that a customer may utilize an approved backflow preventer providing greater protection than required by Section 7604. Such backflow preventers shall be installed by and at the expense of the customer, in a (N)

(continued)

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice Letter No. 251

M. L. Whitehead

Date Filed Feb. 5, 1990

Decision No. _____

NAME

Effective Jan 9, 1990

President

TITLE

Resolution No. _____