

**Rule No. 15**  
**MAIN EXTENSIONS**  
*(continued)*

A. General Provisions and Definitions

4. Ownership, Design, and Construction of Facilities

d. When an extension must comply with an ordinance, regulation, or specification of a public authority, the estimated and adjusted construction costs of said extension shall be based upon the facilities required to comply therewith.

e. If the following provisions for water conservation are included in local building codes and/or ordinances the main extension contract shall contain these provisions.

1) All interior plumbing in new buildings shall meet the following requirements:

a) Toilets shall not use more than 3½ gallons per flush, except that toilets and urinals with flush valves may be installed.

b) Shower heads shall contain flow controls which restrict flow to a maximum of approximately 3 gallons per minute.

c) Kitchen and lavatory faucets shall have flow controls which restrict flow to a maximum of approximately 2 gallons per minute.

2) All new parks, median strips, landscaped public areas and landscaped areas surrounding condominiums, townhouses, apartments, and industrial parks shall have a well-balanced automatic irrigation system designed by a landscape architect or other competent person, and shall be operated by electric time controller stations set for early morning irrigation.

5. Estimates, Plans, and Specifications

a. Upon request by a potential applicant for a main extension of 100 feet or less, the utility shall prepare, without charge, a preliminary sketch and rough estimates of the cost of installation to be advanced by said applicant.

(C)  
(C)

*(continued)*

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice Letter No. 258

M. L. Whitehead

Date Filed Dec. 3, 1991

Decision No. 91-04-068

NAME

Effective May 24, 1991

President

TITLE

Resolution No.