

Rule No. 18

METER TESTS AND ADJUSTMENT OF BILLS FOR METER ERROR

(continued)

4. Return of Deposit

fast. The customer will be notified not less than five days in advance of the time and place of the test.

5. Location of Test

A customer will have the right to require the utility to conduct the test in such customer's presence or in the presence of a representative of such customer. Where the utility has no proper meter testing facilities available locally, the meter may be tested by a meter manufacturer or its agency, or by any other reliable organization equipped for water meter testing or by the utility's meter testing plant where located in some other community, in which latter case the utility upon demand of the customer will furnish the customer with a notarized statement certifying as to the method used in making the test and as to the accuracy of the meter.

6. Report of Test to Customer

A report showing the results of the test will be furnished to the customer within 15 days after the completion of the test.

B. Adjustment of Bills for Meter Error

1. Fast Meters

When, upon test, a meter is found to be registering more than 2% fast, the utility will refund to the customer the amount of the overcharge based on corrected meter readings for the period the meter was in use but not to exceed a period of six months.

2. Slow Meters

a. Commercial Service

When, upon test, a meter for commercial (residential and business) service is found to be registering more than 25% slow, the utility may bill the customer for the amount of the undercharge based upon corrected meter readings for the period the meter was in service but not to exceed a period of three months.

(continued)

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice Letter No. 52

J. E. Skelton

Date Filed Feb. 28, 1963

Decision No. 64572

NAME

Effective Mar 4, 1963

Vice President

TITLE

Resolution No. _____