

SCHEDULE NO. FO-4
Fontana Water Company
PRIVATE FIRE SERVICE

APPLICABILITY

Applicable to water service furnished to private fire systems and to private fire hydrants.

TERRITORY

Portions of Fontana, Rancho Cucamonga, Rialto and vicinity, San Bernardino County.

RATE

Per Service
Per Month

For each inch of diameter of service connection \$13.46 (1)

SPECIAL CONDITIONS

1. The customer will pay, without refund, the entire cost of the private fire service facilities.
2. The private fire service facilities shall be installed by the utility or under the utility's direction and shall be the sole property and subject to the control of the utility, with the right to alter, repair, replace and the right to remove upon discontinuance of service.
3. The minimum diameter for the private fire service connection will be 4-inches. The maximum diameter shall not be larger than the diameter of the water main to which the private fire service facilities are attached unless said main is circulating, in which case with the approval of the utility the maximum diameter may be larger by not more than 2-inches than the diameter of said circulating main.
4. If a water main of adequate size is not available adjacent to the premises to be served, then a new main from the nearest existing main of adequate size will be installed by the utility at the cost of the customer. Such cost shall not be subject to refund.
5. The private fire service facilities will include a detector check valve or other similar device acceptable to the utility which will indicate the use of water. The facilities may be located within the customer's premises or within public right of way adjacent thereto. Where located within the premises, the utility and its duly authorized agents shall have the right of ingress to and egress from the premises for all purposes related to said facilities. In the event the installation is solely a private fire hydrant facility, the requirement for a detector check valve or other similar device may be waived.

(continued)

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice Letter No. 564

J. M. Reiker

Date Filed 05/17/2021

Decision No. _____

NAME

Effective 07/01/2021

Vice President of Regulatory Affairs

TITLE

Resolution No. _____

11142 GARVEY AVENUE
EL MONTE, CALIFORNIA 91733

Revised
Cancelling Revised

Cal. P.U.C. Sheet No. 1087-W

Cal. P.U.C. Sheet No. 683-W

Schedule No. FO-4
Fontana Water Company

PRIVATE FIRE SERVICE

SPECIAL CONDITIONS - Continued

6. No structure shall be built over the private fire service facilities and the customer shall maintain and safeguard the area occupied by the private fire service facilities from traffic and other hazardous conditions. The customer will be responsible for any damage to the private fire service facilities whether resulting from the use or operation of appliances and facilities on customer's premises or otherwise. (T)

7. Subject to the approval of the utility, any change in the location or construction of the private fire service facilities as may be requested by public authority or the customer will be made by the utility following payment to the utility of the entire cost of such change. (T)

8. The customer's installation must be such as to separate effectively the private fire service facilities from that of the customer's regular domestic water service. Any unauthorized use of water from the private fire service facilities will be charged for at the applicable tariff rates and may be grounds for the utility's discontinuing private fire service without liability to the utility. (T)

9. There shall be no cross connection between the systems supplied by water through the utility's private fire service facilities and any other source of supply without the specific approval of the utility. The specific approval, if given, will at least require at the customer's expense, a special double check valve installation or other backflow prevention device acceptable to the utility. Any unauthorized cross connection may be grounds for immediately discontinuing private fire service without liability to the utility. (T)

10. The utility will supply only such water at such pressure as may be available from time to time as a result of its operation of the system. The customer shall indemnify the utility and save it harmless against any and all claims arising out of service under this schedule and shall further agree to make no claims against the utility for any loss or damage resulting from service under this schedule. Section 774 of the Public Utilities Code limits the liability of the utility resulting from a claim regarding adequacy of pressure or supply for fire protection service. (T)

11. The customer shall be responsible for the periodic testing of any backflow prevention devices as required by public authority or the utility. Any repair or replacement of such devices or of any other facilities installed to provide private fire service shall be done at the customer's expense. Any refusal to comply with the above requirements may be grounds for the utility's discontinuing private fire service without liability to the utility. (T)

(To be inserted by utility)

Issued by

(To be inserted by Cal. P.U.C.)

Advice Letter No. 223

R. E. Heytens

Date Filed JAN 29 1986

Decision No.

NAME
Vice President

Effective FEB 28 1986

Resolution No.

SCHEDULE NO. FO-4
Fontana Water Company
PRIVATE FIRE SERVICE
(continued)

SPECIAL CONDITIONS – continued

- 12. As authorized by the California Public Utilities Commission, all bills are subject to a one-time surcharge of \$2.02. This charge offsets the Department of Health Services fee and certain water testing expenses incurred under the Environmental Protection Agency's adopted National Primary Drinking Water Regulations. (C)
| (C)
- 13. All bills are subject to the reimbursement fee set forth on Schedule No. AA-UF.

(To be inserted by utility)

Advice Letter No. 301

Decision No. _____

Issued by

M. L. Whitehead
NAME

President
TITLE

(To be inserted by Cal. P.U.C.)

Date Filed AUG 08 1998

Effective SEP 15 1998

Resolution No. W 4013